

CQI WATER TREATMENT

11 Cindy Lane, Ocean NJ 07712
PO Box 1140 Oakhurst NJ 07755
Phone (732) 493-4002 Fax (732) 493-4425

Domestic Water Lead (Bp) Testing ***Fair Haven School District***

Building	Sample Location	Date	Time	Natl. Standard	Detection Level	Result
Knollwood School	98 Wing 1 st Sample	3/28/16	7:20	0.015mg/l	<15ppb	ND
Knollwood School	98 Wing 2nd Sample	3/28/16	7:20	0.015mg/l	<15ppb	ND
Knollwood School	65 Wing 1 st Sample	3/28/16	7:20	0.015mg/l	<15ppb	ND
Knollwood School	65 Wing 2nd Sample	3/28/16	7:20	0.015mg/l	<15ppb	ND
Knollwood School	55 Wing 1 st Sample	3/28/16	7:20	0.015mg/l	<15ppb	ND
Knollwood School	55 Wing 2nd Sample	3/28/16	7:20	0.015mg/l	<15ppb	ND
Knollwood School	50 Wing 1 st Sample	3/28/16	7:20	0.015mg/l	<15ppb	ND
Knollwood School	50 Wing 2nd Sample	3/28/16	7:20	0.015mg/l	<15ppb	ND
Sickles School	1 st Floor 1 st Sample	3/28/16	7:45	0.015mg/l	<15ppb	ND
Sickles School	1 st Floor 2nd Sample	3/28/16	7:45	0.015mg/l	<15ppb	ND
Sickles School	2 nd Floor 1 st Sample	3/28/16	7:45	0.015mg/l	<15ppb	ND
Sickles School	2 nd Floor 2nd Sample	3/28/16	7:45	0.015mg/l	<15ppb	ND

INDEX: **POS = The lead level was detected above the minimum detection level**
 ND = The lead level was not detected above the minimum detection level